

FXLJ-F 12/20kV Cable



Eland Product Group: B1H

APPLICATION

This cable is designed for installation hanging in poles. The cable can also be used for plowing in ground and for sea laying.

CHARACTERISTICS

Voltage Rating U_o/U
12/20 (24)kV

Temperature Rating
Minimum installation: -20°C
Maximum Operating: 90°C

Minimum Bending Radius
Fixed: 8 x overall diameter
During extraction: 12 x diameter
When plowing: 8 x overall diameter

CONSTRUCTION

Conductor

Class 2 threaded, round and compressed copper, long waterproof

Inner Semi-Conductive Layer

Insulation

XLPE (Cross-Linked Polyethylene)

Outer Semi-Conductive Layer

Tape

Screen

Annealed copper wires

Outer Sheath

PE (Polyethylene)

Sheath Colour

● Black

STANDARDS

SS 424 14 16, HD 620 Part 10 Section M, SS 424 14 75, IEC 60228

THE CABLE LAB[®]

AN ISO/IEC 17025 AND IECCE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT

We are on a journey to Net Zero.

We've committed to near-term emissions reductions and a net-zero target with the Science Based Targets initiative and we're a signatory to the United Nations Global Compact Sustainable Development Goals.

Learn more about embodied carbon and our carbon emissions reduction actions, our comprehensive recycling services, and wider ESG activities for sustainable operations at: www.elandcables.com/company/about-us/esg-sustainability



REGULATORY COMPLIANCE

This cable is compliant with European Regulation EN 50575, the Construction Products Regulation.



This cable meets the requirements of the RoHS Directive 2015/65/EU and Reach Directive EC 1907/2006. RoHS compliance has been tested and confirmed by The Cable Lab[®].





DIMENSIONS

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL THICKNESS OF INSULATION mm	NOMINAL DIAMETER OVER INSULATION mm	NOMINAL OVERALL DIAMETER mm	NOMINAL WEIGHT kg/km
B1H20KV03010/10BK	3	10/10	4.85	16	44	1320

ELECTRICAL DATA

WIRE RESISTNCE W/km	SCREEN RESISTNCE W/km	INDUCTANCE mH/km	REACTANCE W/km	CAPACITANCE mF/km	CAPACITIVE CHARGE CURRENT/PHRASE A/km	CAPACITIVE EARTH CURRENT A/km
1.83	2	0.48	0.15	0.11	0.4	1.2

DATA FOR PREPARATION AND INSTALLATION

SPAN LENGTH	SUSPENSION AT +60°C m	SUSPENSION AT -40°C m	TRACTION FORCE AT 0°C AND ICE LOAD 2KG/M kN
50	1.86	1.06	6.4
60	2.20	1.29	7.4
70	2.53	1.51	8.3
80	2.86	1.74	9.1

DATA FOR PREPARATION AND INSTALLATION

CABLE TEMPERATURE °C	TRACTION FORCE kN	SUSPENSION AT 50M SPAN m	SUSPENSION AT 60M SPAN m	SUSPENSION AT 70M SPAN m	SUSPENSION AT 80M SPAN m
20	4.5	0.95	1.37	1.87	2.44
10	4.6	0.89	1.29	1.75	2.36
0	4.8	0.86	1.24	1.69	2.29
-10	4.9	0.85	1.22	1.66	2.21
-15	5.1	0.83	1.20	1.63	2.13

Max conductor temperature 90° C
 - Ground temperature 15 ° C
 - Air temperature 20 ° C
 - Ground heat resistivity 1.0 ° K * m / W
 - Laying depth 0.65 m
 - Frequency 50 Hz