

RHZ1-20L-AL Cable



Eland Product Group:

APPLICATION

Halogen Free Medium voltage cables with additional waterblocking properties for distribution networks; also for connection to generation units and plant and process connection. To be laid directly in ground, outdoors, indoors and in cable ducts.

CHARACTERISTICS

Voltage Rating U_o/U (Um)

8.7/15 (17.5) kV
12/20(24) kV
18/30(36) kV

Temperature Rating

-20°C to +90°C

Minimum Bending Radius

15 x overall diameter

CONSTRUCTION

Conductor

Class 2 stranded aluminium with longitudinal water tightness

Conductor Screen

Semi-conductive material

Insulation

XLPE (Cross-Linked Polyethylene)

Insulation Screen

Semi-conductive material

Longitudinal Waterblocking

Water-swellable tape

Screen

Copper wires

Longitudinal Waterblocking

Water-swellable tape

Sheath

PO (Polyolefin) DMZ1 ST7

Sheath Colour

● Red

STANDARDS

IEC 60502-2, HD 620 10E-1

Halogen Free- IEC 60754-1/2,

UV Resistant: UNE 21 1605, HD 605, Subclause 2.2.13

THE CABLE LAB[®]

AN ISO/IEC 17025 AND IECEE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT

We are on a journey to Net Zero.

We've committed to near-term emissions reductions and a net-zero target with the Science Based Targets initiative and we're a signatory to the United Nations Global Compact Sustainable Development Goals.

Learn more about embodied carbon and our carbon emissions reduction actions, our comprehensive recycling services, and wider ESG activities for sustainable operations at: www.elandcables.com/company/about-us/esg-sustainability



REGULATORY COMPLIANCE

This cable is compliant with European Regulation EN 50575, the Construction Products Regulation.



This cable meets the requirements of the RoHS Directive 2015/65/EU and Reach Directive EC 1907/2006. RoHS compliance has been tested and confirmed by The Cable Lab[®].





DIMENSIONS 8.7/15 (17.5)KV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL CONDUCTOR DIAMETER mm	NOMINAL INSULATION THICKNESS mm	NOMINAL DIAMETER OVER INSULATION mm	NOMINAL METALLIC SCREEN CROSS SECTION mm ²	NOMINAL OUTER SHEATH THICKNESS mm	NOMINAL OUTER DIAMETER mm	NOMINAL WEIGHT kg/km
H7A15KV01050	1	50	8.0	4.5	18.2	16	2.5	28.1	720
H7A15KV01095	1	95	11.2	4.5	21.4	16	2.5	31.2	1100
H7A15KV01150	1	150	14.0	4.5	24.2	16	2.7	34.1	1440
H7A15KV01240	1	240	17.9	4.5	28.1	16	3.0	37.8	1780
H7A15KV01400	1	400	23.1	4.5	33.3	16	3.0	42.8	2300
H7A15KV 01630	1	630	29.1	4.5	39.6	16	3.0	50.3	3190

ELECTRICAL CHARACTERISTICS 8.7/15 (17.5)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM DC CONDUCTOR RESISTANCE AT 20°C ohm/km	NOMINAL AC CONDUCTOR RESISTANCE AT 90°C ohm/km	MAXIMUM METALLIC SCREEN RESISTANCE AT 20°C ohm/km	INDUCTANCE IN TREFOIL mH/km	CAPACITANCE µF/km	CURRENT RATING A		MAXIMUM SHORT-CIRCUIT CURRENT DURING 1 SECOND kA	
						In air trefoil	Buried in soil	Conductor	Screen
50	0.641	0.822	1.15	0.42	0.20	170	140	4.7	2.4
95	0.320	0.411	1.15	0.37	0.25	255	205	9.0	2.4
150	0.206	0.265	1.15	0.35	0.30	335	260	14.2	2.4
240	0.125	0.161	1.15	0.32	0.36	455	345	22.7	2.4
400	0.0778	0.102	1.15	0.30	0.44	610	445	37.8	2.4
630	0.0469	0.064	1.15	0.28	0.54	830	575	59.5	2.4

In Air - +40°C Trefoil Buried in soil at +25°C, depth 1m, thermal resistivity 1.5k m/W

MECHANICAL CHARACTERISTICS 8.7/15 (17.5)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM PULLING EFFORT - CONDUCTOR dAN	MINIMUM BENDING RADIUS mm	
		During installation	After Installation
		50	150
95	285	624	468
150	450	682	511
240	720	756	567
400	1200	856	642
630	1890	1006	755



DIMENSIONS 12/20 (24)KV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL CONDUCTOR DIAMETER mm	NOMINAL INSULATION THICKNESS mm	NOMINAL DIAMETER OVER INSULATION mm	NOMINAL METALLIC SCREEN CROSS SECTION mm ²	NOMINAL OUTER SHEATH THICKNESS mm	NOMINAL OUTER DIAMETER mm	NOMINAL WEIGHT kg/km
H7A20KV01050	1	50	8.0	5.5	20.2	16	2.5	28.0	850
H7A20KV01095	1	95	11.2	5.5	23.4	16	2.7	32	1100
H7A20KV01150	1	150	14.0	5.5	26.2	16	3.0	34.0	1400
H7A20KV01240	1	240	17.9	5.5	30.1	16	3.0	38.0	1800
H7A20KV01400	1	400	23.1	5.5	35.3	16	3.0	43.0	2500
H7A20KV 01630	1	630	29.1	5.5	41.6	16	3.0	50.0	3500

ELECTRICAL CHARACTERISTICS 12/20 (24)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM DC CONDUCTOR RESISTANCE AT 20°C ohm/km	NOMINAL AC CONDUCTOR RESISTANCE AT 90°C ohm/km	MAXIMUM METALLIC SCREEN RESISTANCE AT 20°C ohm/km	INDUCTANCE IN TREFOIL mH/km	CAPACITANCE µF/km	CURRENT RATING A		MAXIMUM SHORT-CIRCUIT CURRENT DURING 1 SECOND kA	
						In air	Buried in soil	Conductor	Screen
50	0.641	0.822	1.15	0.43	0.18	170	140	4.7	2.4
95	0.320	0.411	1.15	0.39	0.22	255	205	9.0	2.4
150	0.206	0.265	1.15	0.36	0.26	335	260	14.2	2.4
240	0.125	0.161	1.15	0.34	0.31	455	345	22.7	2.4
400	0.0778	0.102	1.15	0.31	0.37	610	445	37.8	2.4
630	0.0469	0.063	1.15	0.29	0.45	830	575	59.5	2.4

In Air - +40°C Trefoil Buried in soil at +25°C, depth 1m, thermal resistivity 1.5k m/W

MECHANICAL CHARACTERISTICS 12/20 (24)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM PULLING EFFORT - CONDUCTOR dAN	MINIMUM BENDING RADIUS mm	
		During installation	After Installation
50	150	560	420
95	285	640	480
150	450	680	510
240	720	760	570
400	1200	860	645
630	1890	1000	750

DIMENSIONS 18/30 (36)KV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL CONDUCTOR DIAMETER mm	NOMINAL INSULATION THICKNESS mm	NOMINAL DIAMETER OVER INSULATION mm	NOMINAL METALLIC SCREEN CROSS SECTION mm ²	NOMINAL OUTER SHEATH THICKNESS mm	NOMINAL OUTER DIAMETER mm	NOMINAL WEIGHT kg/km
H7A30KV01050	1	50	8.0	8.0	25.2	16	2.7	32.0	900
H7A30KV01095	1	95	11.2	8.0	28.4	16	3.0	35.0	1200
H7A30KV01150	1	150	14.0	8.0	31.2	16	3.0	38.0	1500
H7A30KV01240	1	240	17.9	8.0	35.1	16	3.0	43.0	1900
H7A30KV01400	1	400	23.1	8.0	40.3	16	3.0	48.0	2750
H7A30KV 01630	1	630	29.1	8.0	46.6	16	3.0	56.0	3500

ELECTRICAL CHARACTERISTICS 18/30 (36)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM DC CONDUCTOR RESISTANCE AT 20°C ohm/km	NOMINAL AC CONDUCTOR RESISTANCE AT 90°C ohm/km	MAXIMUM METALLIC SCREEN RESISTANCE AT 20°C ohm/km	INDUCTANCE IN TREFOIL mH/km	CAPACITANCE µF/km	CURRENT RATING A		MAXIMUM SHORT-CIRCUIT CURRENT DURING 1 SECOND kA	
						In air	Buried in soil	Conductor	Screen
50	0.641	0.822	1.15	0.47	0.14	170	140	4.7	2.4
95	0.320	0.411	1.15	0.42	0.17	255	205	9.0	2.4
150	0.206	0.265	1.15	0.39	0.19	335	260	14.2	2.4
240	0.125	0.161	1.15	0.36	0.23	455	345	22.7	2.4
400	0.0778	0.101	1.15	0.33	0.27	610	445	37.8	2.4
630	0.0469	0.063	1.15	0.31	0.33	830	575	59.5	2.4

In Air - +40°C Trefoil Buried in soil at +25°C, depth 1m, thermal resistivity 1.5k m/W

MECHANICAL CHARACTERISTICS 18/30 (36)KV

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM PULLING EFFORT - CONDUCTOR dAN	MINIMUM BENDING RADIUS mm	
		During installation	After Installation
		50	150
95	285	700	525
150	450	760	570
240	720	860	645
400	1200	960	720
630	1090	1120	840

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.