

RHZ1-OL (S) Cable



ELAND CABLES Ø



Eland Product Group: H6G

APPLICATION

Medium voltage power cables for distribution networks and generation units. LSZH outer sheathing makes the cable suitable for internal installation as well as directly in ground, outdoors, and in cable ducts. UV Resistant.

CHARACTERISTICS

Voltage Rating Uo/U (Um) 6/10 (12)kV 8.7/15 (17.5) kV 12/20 (24)kV 18/30 (36)kV

Test Voltage:

21kV AC 50Hz (5 mins) 30.45kV AC 50Hz (5 mins) 42kV AC 50Hz (5 mins) 63kV AC 50Hz (5 mins)

Temperature Rating

-20°C to +60°C Permissible Conductor Operating Temperature: +90°C Permissible Short Circuit Temperature up to 5 sec: 250°C

Minimum Bending Radius

15 x overall diameter

CONSTRUCTION

Conductor Class 2 Stranded Copper

Conductor Screen Semi-conductive material

Insulation XLPE (Cross-Linked Polyethylene)

Insulation Screen Semi-conductive material (bonded)

Longitudinal Waterblocking Semi-conductive swellable tape

Screen Copper wires and copper tape

Longitudinal Waterblocking Swellable Tapes

Outer Sheath LSZH (Low Smoke Zero Halogen)



STANDARDS

IEC 60502-2, IEC 60228,

Generally to HD620 10E-1

Low Smoke Zero Halogen: IEC 60754-1/2, IEC 61034-2 Flame Retardant: IEC 60332-1-2 UV Resistant: ISO 4892-3 Abrasion and Tear Resistant: EN 60229-4.1 Impact rated to: AG2 EN 60364-5.51

THE CABLE LAB® AN ISO/IEC 17025 AND IECEE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT

We are on a journey to Net Zero.

We've committed to near-term emissions reductions and a net-zero target with the Science Based Targets initiative and we're a signatory to the United Nations Global Compact Sustainable Development Goals.

Learn more about embodied carbon and our carbon emissions reduction actions, our comprehensive recycling services, and wider ESG activities for sustainable operations at: www.elandcables.com/company/about-us/esg-sustainability



REGULATORY COMPLIANCE

This cable is compliant with European Regulation EN 50575, the Construction Products Regulation.



This cable meets the requirementsof the Low VoltageDirective 2014/35/EU, the RoHS Directive 2015/65/EU and Reach Directive EC 1907/2006. RoHS compliance has been tested and confirmed by The Cable Lab®.



DIMENSIONS 6/10 (12)KV

ELAND PART NO	D.	NO. OF	NOMINAL (SECTION,		NOMINAL CONDUCTOR	NUMBER WIRES	NOM. THICKNESS SEMI-CON. LAYER		NOMINAL INSULATION	MINIMUM INSULATION	NOMINAL DIAMETER OVER
		CORES	mr		DIAMETER	CONDUCTOR	INNER	OUTER	THICKNESS	THICKNESS	INSULATION
			Conductor	Screen	mm	mm	mm	mm	mm	mm	mm
H6G10KV015	500	1	500	35	26.5	61 x 3.29	0.50	0.40	3.40	2.96	34.7
H6G10KV016	530	1	630	35	30.2	61 x 3.80	0.50	0.40	3.40	2.96	38.9
NOMINAL CROSS SECTIONAL AREA	Ŵ	MBER /IRES REEN	1	METER FAPE REEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNES		NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm²		mm		mm	mm	mm		mm	kg/km	N/cm ²	Ν
500	60	x 0.85	1x(0.1x15	2.30	1.64		42	5500	2443	25000
630	60	x 0.85	1x(D.1x15	2.40	1.72		46	6750	2756	31500

ELECTRICAL CHARACTERISTICS 6/10 (12)KV

NOMINAL CROSS SECTIONAL AREA	CONDUCTOR DC RESISTANCE AT 20°C	CONDUCTOR DC RESISTANCE AT 75°C	CONDUCTOR AC RESISTANCE BY MAX TEMP		CARRYING CITY (A)	REACTANCE	CHARGING ADMITTANCE	CAPACITANCE	S.C.C CONDUCTOR 1SEC kA	S.C.C SCREEN 1SEC	CONDUCTOR LOSSES IN THE GROUND
mm ²	ohms/km	ohms/km	ohms/km	llmGround 20°C	In Air 30°C	ohms/km	A/km	uF/km	KA	kA	kW/km
500	0.0366	0.0758	0.0510	743	1006	0.15	0.28	0.54	71.50	7.1	28.2
630	0.0283	0.0420	0.0586	850	1030	0.14	0.25	0.62	90.09	7.1	30.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching) Derating factor (air): 1 (Flat formation - touching)

DIMENSIONS 8.7/15 (17.5)KV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL DIAMETER OF CONDUCTOR mm		INSULATION METALLIC SCREEN		SCREEN	NOMINAL OUTER DIAMETER OF CABLE mm	NOMINAL WEIGHT kg/km	MAXIMUM PULLING FORCE kN	MINIMUM BENDING RADIUS m
				Nominal thickness	Nominal diameter over	Nominal cross section mm ²	Nominal diameter over mm				
H6G15KV01500	1	500	26.5	4.5	37.2	50	41.5	47.1	5810	25	0.71
H6G15KV01630	1	630	30.3	4.5	41.3	50	45.6	51.3	7160	31.5	0.77

ELECTRICAL CHARACTERISTICS 8.7/15 (17.5)KV

NOMINAL CROSS SECTIONAL AREA CONDUCTOR/ METALLIC	MAXIMUM CONDUCTOR DC RESISTANCE AT 20 °C	MAXIMUM CONDUCTOR AC RESISTANCE AT 90 °C	MAXIMUM METALLIC SCREEN DC RESISTANCE AT 20°C	MAXIMUM METALLIC SCREEN AC RESISTANCE AT 80 °C		RICAL STRESS	RESISTANCE Ω/km	CAPACITANCE µF/km	CAPACITANCE REACTANCE Ω/km	CHARGING CURRENT A/km	REACTANCE Ω/km
SCREEN mm ²	Ω/km	Ω/km	Ω/km	Ω/km	Conductor screen	Insulation					
500/50	0.0366	0.0505	0.36	0.44	2.17	1.63	0.49	0.44	7.2	1.21	0.042
630/50	0.0283	0.0410	0.36	0.44	2.13	1.65	0.48	0.50	6.4	1.37	0.040

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.



ELAN	D
CABL	25

NOMINAL CROSS SECTIONAL AREA CONDUCTOR/ METALLIC SCREEN mm ²		INDUCTANCE L mH/km		INC	DUCTANCE REACTA XL ohm/mm	NCE	IMPEDANCE ohm/km			
	002	ංංං	೦೦ರೆ	° ° ° ° ° ° ° ° ° ° ° ° ° ° ° ° ° ° °	ංංථ	ంంరే	୦ ୦୦ଥ	ංංං	೦೦೦	
500/50	0.30	0.53	0.48	0.095	0.167	0.153	0.107	0.175	0.162	
630/50	0.29	051	0.47	0.092	0.161	0.150	0.101	0.166	0.156	

2 - Cables in trefoil formation, the distance between cables De

3 - Cables in flat formation (in the ground), the distance between cables De + 70 mm

4 - Cables in flat formation (in the air), the distance between cables 2 x De

CURRENT RATING FOR SINGLE-CORE CABLES-AMPERES

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM SHORT CIRCUIT CAPACITY CONDUCTOR kA/sec	MAXIMUM SHORT CIRCUIT CAPACITY SCREEN kA/sec	FLAT FOR	RMATION	TREFOIL F	ORMATION	FLAT FOR	MATION	TREFOIL FORMATION		
						CONFIGU	JRATIONS				
			SPP;CB	BOTH-ENDS	SPP;CB	BOTH-ENDS	SPP;CB	BOTH-ENDS	SPP;CB	BOTH-ENDS	
				CABLES	IN EARTH			CABLES	s in air		
500/50	71.5	9.8	1100	861	1011	966	1294	1056	1061	1016	
630/50	90.1	9.8	1256	947	1144	1083	1508	1184	1224	1164	

SPB - Single Point Bonding; CB - Cross-bonding Both-ends; BE - Both-ends bonding

Laying conditions at trefoil formation are as below:

•Soil thermal resistivity: 1 /2.5 k m/W

•Burial depth: 0.7m

•Ground temperature: 20°C I Ambient temperature: 30°C

DIMENSIONS 12/20 (24)KV

ELAND PART NO.	NO. OF CORES	NOMINAL C SECTIONA	AL AREA	NOMINAL CONDUCTOR DIAMETER	NDUCTOR WIRES SEMI-CON. L			NOMINAL INSULATION THICKNESS	MINIMUM INSULATION THICKNESS	NOMINAL DIAMETER OVER INSULATION	
		Conductor	Screen	mm	r	mm	mm	mm	mm	mm	mm
H6G20KV01500	1	500	35	26.5	61 x 3	3.29	0.50	0.40	5.50	4.85	38.7
H6G20KV01630	1	630	35	30.2	61 x 3	3.80	0.50	0.40	5.50	4.85	42.9

NOMINAL CROSS SECTIONAL AREA	NUMBER WIRES SCREEN	DIAMETER TAPE SCREEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNESS	NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm²	mm	mm	mm	mm	mm	kg/km	N/cm ²	Ν
500	60 × 0.85	1x0.1x15	2.40	1.72	48	5750	2299	25000
630	60 x 0.85	1x0.1x15	2.50	1.80	51	7000	2586	31500

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.



ELECTRICAL CHARACTERISTICS 12/20 (24)KV

NOMINAL CROSS SECTIONAL AREA	CONDUCTOR DC RESISTANCE AT 20°C	CONDUCTOR DC RESISTANCE AT 75°C	CONDUCTOR AC RESISTANCE BY MAX TEMP		CARRYING CITY (A)	REACTANCE	CHARGING ADMITTANCE	CAPACITANCE	S.C.C CONDUCTOR 1SEC	S.C.C SCREEN 1SEC	CONDUCTOR LOSSES IN THE GROUND
mm ²	ohms/km	ohms/km	ohms/km	lmGround 20°C	In Air 30°C	ohms/km	A/km	uF/km	kA	kA	kW/km
500	0.0366	0.0758	0.0510	756	1011	0.15	0.28	0.36	71.50	7.1	29.1
630	0.0283	0.0420	0.0586	850	1030	0.15	0.27	0.40	90.09	7.1	30.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching) Derating factor (air): 1 (Flat formation - touching)

DIMENSIONS 18/30 (36)KV

ELAND PART NO.	NO. OF CORES	SECTION	NOMINAL CROSS SECTIONAL AREA mm ²		NOMINAL CONDUCTOR DIAMETER NUMBER WIRES CONDUCTOR		CKNESS I. LAYER	NOMINAL INSULATION THICKNESS	MINIMUM INSULATION THICKNESS	NOMINAL DIAMETER OVER INSULATION
	CORES	Conductor	Screen	mm	mm	INNER mm	OUTER	mm	mm	mm
H6G30KV01500	1	500	35	26.5	61 x 3.29	0.50	0.40	8.00	7.10	43.5
H6G30KV01630	1	630	35	30.2	61 x 3.80	0.50	0.40	8.00	7.10	47.7

NOMINAL CROSS SECTIONAL AREA	NUMBER WIRES SCREEN	DIAMETER TAPE SCREEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNESS	NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm²	mm	mm	mm	mm	mm	kg/km	N/cm ²	Ν
500	60 x 0.85	1x0.1x15	2.60	1.88	51	6000	2151	25000
630	60 x 0.85	1x0.1x15	2.70	1.96	56	7500	2436	31500

ELECTRICAL CHARACTERISTICS 18/30 (36)KV

NOMINAL CROSS SECTIONAL AREA	CONDUCTOR DC RESISTANCE AT 20°C	CONDUCTOR DC RESISTANCE AT 75°C	CONDUCTOR AC RESISTANCE BY MAX TEMP	CURRENT CARRYING CAPACITY (A)		REACTANCE	CHARGING ADMITTANCE	CAPACITANCE	S.C.C CONDUCTOR 1SEC	S.C.C SCREEN 1SEC	CONDUCTOR LOSSES IN THE GROUND
mm ²	ohms/km	ohms/km	ohms/km	lmGround 20°C	In Air 30°C	ohms/km	A/km	uF/km	kA	kA	kW/km
500	0.0366	0.0758	0.0510	768	1011	0.16	0.30	0.26	71.50	7.1	30.1
630	0.0283	0.0420	0.0586	850	1030	0.16	0.29	0.29	90.09	7.1	30.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching) Derating factor (air): 1 (Flat formation - touching)

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.