



Eland Product Group: P9X

APPLICATION

Medium voltage power cables with additional waterblocking properties for distribution networks and generation units, suitable for external installation including in direct in ground and in buried cable ducts. UV Resistant.

CHARACTERISTICS

Voltage Rating U₀/U (Um)

6/10 (12)kV
8.7/15 (17.5)kV
12/20 (24)kV
18/30 (36)kV

Test Voltage

10kV: 21 kV AC 50Hz (15 mins)
20kV: 42kV AC 50Hz (5 mins)
30kV: 63kV AC 50Hz (5 mins)

Temperature Rating

-20°C to +60°C
Permissible Conductor Operating Temperature: +90°C
Permissible Short Circuit Temperature up to 5 sec: 250°C

Minimum Bending Radius

15 x overall diameter

CONSTRUCTION

Conductor

Class 2 Stranded Aluminium

Conductor Screen

Semi-conductive material

Insulation

XLPE (Cross-Linked Polyethylene)

Insulation Screen

Semi-conductive material (bonded)

Longitudinal Waterblocking

Semi-conductive swellable tape

Screen

Copper wires and copper tape

Longitudinal Waterblocking

Swellable Tapes

Outer Sheath

MDPE (Medium Density Polyethylene)

Sheath Colour

● Red ● Black

STANDARDS

IEC 60502-2, Generally to PN HD 620 10R

UV Resistant: ISO 4892-3

Abrasion and Tear Resistant: EN 60229-4.1

Impact rated to: AG2 EN 60364-5.51

THE CABLE LAB[®]

AN ISO/IEC 17025 AND IECEE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT

We are on a journey to Net Zero.

We've committed to near-term emissions reductions and a net-zero target with the Science Based Targets initiative and we're a signatory to the United Nations Global Compact Sustainable Development Goals.

Learn more about embodied carbon and our carbon emissions reduction actions, our comprehensive recycling services, and wider ESG activities for sustainable operations at: www.elandcables.com/company/about-us/esg-sustainability



REGULATORY COMPLIANCE

This cable meets the requirements of the RoHS Directive 2015/65/EU and Reach Directive EC 1907/2006. RoHS compliance has been tested and confirmed by The Cable Lab[®].





DIMENSIONS 6/10 (12)kV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA		NOMINAL CONDUCTOR DIAMETER	NUMBER WIRES CONDUCTOR	NOM. THICKNESS SEMI-CON. LAYER		NOMINAL INSULATION THICKNESS	MINIMUM INSULATION THICKNESS	NOMINAL DIAMETER OVER INSULATION
		mm ²				INNER	OUTER			
		Conductor	Screen							
P9XAF10KV1050	1	50	16	8.20	7 x 2.90	0.50	0.40	3.40	2.96	16.4
P9XAF10KV1070	1	70	16	9.70	19 x 2.18	0.50	0.40	3.40	2.96	17.9
P9XAF10KV1095	1	95	16	11.4	19 x 2.55	0.50	0.40	3.40	2.96	19.6
P9XAF10KV1120	1	120	16	12.65	19 x 2.90	0.50	0.40	3.40	2.96	20.9
P9XAF10KV1150	1	150	25	14.4	19 x 3.16	0.50	0.40	3.40	2.96	22.6
P9XAF10KV1185	1	185	25	15.75	37 x 2.55	0.50	0.40	3.40	2.96	24.4
P9XAF10KV1240	1	240	25	18.2	37 x 2.90	0.50	0.40	3.40	2.96	26.9
P9XAF10KV1300	1	300	25	20.5	61 x 2.55	0.50	0.40	3.40	2.96	29.2
P9XAF10KV1400	1	400	35	23.0	61 x 2.90	0.50	0.40	3.40	2.96	31.7
P9XAF10KV1500	1	500	35	26.0	61 x 3.20	0.50	0.40	3.40	2.96	34.7
P9XAF10KV1630	1	630	35	30.2	61 x 3.65	0.50	0.40	3.40	2.96	38.9

NOMINAL CROSS SECTIONAL AREA	NUMBER WIRES SCREEN	DIAMETER TAPE SCREEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNESS	NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm ²	mm	mm	mm	mm	mm	kg/km	N/cm ²	N
50	44 x 0.66	1x0.1x10	1.80	1.24	23	550	331	1500
70	44 x 0.66	1x0.1x10	1.80	1.24	24	650	415	2100
95	44 x 0.66	1x0.1x10	1.80	1.24	26	750	522	2850
120	44 x 0.66	1x0.1x10	1.80	1.24	27	850	621	4500
150	71 x 0.66	1x0.1x10	1.90	1.32	29	1100	708	7500
185	71 x 0.66	1x0.1x10	1.90	1.32	31	1200	809	5550
240	71 x 0.66	1x0.1x10	2.00	1.40	33	1400	938	7200
300	71 x 0.66	1x0.1x10	2.10	1.48	36	1600	1081	9000
400	60 x 0.85	1x0.1x15	2.20	1.56	39	2000	1311	12000
500	60 x 0.85	1x0.1x15	2.30	1.64	42	2500	1471	15000
630	60 x 0.85	1x0.1x15	2.40	1.72	46	3000	1654	18900



ELECTRICAL CHARACTERISTICS 6/10 (12)kV

NOMINAL CROSS SECTIONAL AREA mm ²	CONDUCTOR DC RESISTANCE AT 20°C ohms/km	CONDUCTOR DC RESISTANCE AT 75°C ohms/km	CONDUCTOR AC RESISTANCE BY MAX TEMP ohms/km	CURRENT CARRYING CAPACITY (A)		REACTANCE ohms/km	CHARGING ADMITTANCE A/km	CAPACITANCE uF/km	S.C.C CONDUCTOR 1SEC kA	S.C.C SCREEN 1SEC kA	CONDUCTOR LOSSES IN THE GROUND kW/km
				In Ground 20°C	In Air 30°C						
50	0.641	1.32	0.825	194	215	0.18	0.35	0.22	4.70	3.2	31.0
70	0.443	0.917	0.570	236	269	0.17	0.33	0.24	6.58	3.2	31.7
95	0.32	0.662	0.412	281	327	0.17	0.32	0.28	8.93	3.2	32.5
120	0.258	0.524	0.328	318	377	0.16	0.31	0.30	11.28	3.2	33.2
150	0.203	0.426	0.268	350	424	0.16	0.30	0.33	14.10	5.0	32.8
185	0.165	0.339	0.213	393	485	0.16	0.29	0.36	17.39	5.0	32.9
240	0.125	0.258	0.160	453	573	0.15	0.28	0.40	22.56	5.0	33.4
300	0.100	0.207	0.132	507	652	0.15	0.28	0.45	28.20	5.0	33.9
400	0.0778	0.161	0.103	559	741	0.15	0.27	0.49	37.60	7.1	32.2
500	0.0605	0.125	0.0810	622	838	0.15	0.26	0.54	47.00	7.1	31.3
630	0.0469	0.0972	0.0640	701	882	0.14	0.25	0.62	59.22	7.1	47.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching)

Derating factor (air): 1 (Flat formation - touching)



DIMENSIONS 8.7/15 (17.5)kV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL DIAMETER OF CONDUCTOR mm	INSULATION mm		METALLIC SCREEN		NOMINAL OUTER DIAMETER OF CABLE mm	NOMINAL WEIGHT kg/km	MAXIMUM PULLING FORCE kN	MINIMUM BENDING RADIUS m
				Nominal thickness	Nominal diameter over	Nominal cross section mm ²	Nominal diameter over mm				
P9XAF15KV1050	1	50	8.25	4.5	18.5	16	22.6	28.1	720	1.5	0.42
P9XAF15KV1070	1	70	9.5	4.5	19.7	25	23.8	29.4	890	2.1	0.44
P9XAF15KV1095	1	95	11.3	4.5	21.5	35	25.6	31.2	1100	2.85	0.47
P9XAF15KV1120	1	120	12.5	4.5	22.7	50	26.8	32.4	1330	3.6	0.49
P9XAF15KV1150	1	150	14.2	4.5	24.4	50	28.5	34.1	1440	4.5	0.51
P9XAF15KV1185	1	185	15.8	4.5	26.0	50	30.1	35.7	1580	5.55	0.54
P9XAF15KV1240	1	240	17.9	4.5	28.1	50	32.2	37.8	1780	7.2	0.57
P9XAF15KV1300	1	300	20.0	4.5	30.2	50	34.3	39.9	1990	9	0.60
P9XAF15KV1400	1	400	22.9	4.5	33.1	50	37.2	42.8	2300	12	0.64
P9XAF15KV1500	1	500	25.7	4.5	36.4	50	40.7	46.3	2710	15	0.69
P9XAF15KV1630	1	630	29.3	4.5	40.3	50	44.6	50.3	3190	18.9	0.75
P9XAF15KV1800	1	800	33.0	4.5	44.4	50	48.7	54.6	3780	24	0.82
P9XAF15KV11000	1	1000	38.0	4.5	49.4	50	53.7	60.0	4510	30	0.90

ELECTRICAL CHARACTERISTICS 8.7/15 (17.5)kV

NOMINAL CROSS SECTIONAL AREA CONDUCTOR/METALLIC SCREEN mm ²	MAXIMUM CONDUCTOR DC RESISTANCE AT 20 °C Ω/km	MAXIMUM CONDUCTOR AC RESISTANCE AT 90 °C Ω/km	MAXIMUM METALLIC SCREEN DC RESISTANCE AT 20 °C Ω/km	MAXIMUM METALLIC SCREEN AC RESISTANCE AT 80 °C Ω/km	ELECTRICAL FIELD STRESS kV/mm		RESISTANCE Ω/km	CAPACITANCE μF/km	CAPACITANCE REACTANCE Ω/km	CHARGING CURRENT A/km	REACTANCE Ω/km
					Conductor screen	Insulation					
50/16	0.641	0.822	1.12	1.38	2.72	1.37	2.20	0.19	17.2	0.51	0.076
70/25	0.443	0.568	0.72	0.89	2.63	1.40	1.45	0.20	15.7	0.56	0.070
95/35	0.320	0.411	0.51	0.63	2.53	1.45	1.04	0.23	13.9	0.63	0.064
120/50	0.253	0.325	0.36	0.44	2.48	1.47	0.77	0.25	12.9	0.67	0.061
150/50	0.206	0.265	0.36	0.44	2.42	1.51	0.71	0.27	11.8	0.74	0.057
185/50	0.164	0.211	0.36	0.44	2.37	1.53	0.65	0.29	10.9	0.80	0.054
240/50	0.125	0.161	0.36	0.44	2.32	1.56	0.60	0.32	9.9	0.88	0.050
300/50	0.100	0.130	0.36	0.44	2.28	1.59	0.57	0.35	9.1	0.96	0.048
400/50	0.0778	0.102	0.36	0.44	2.24	1.61	0.54	0.39	8.1	1.07	0.044
500/50	0.0605	0.0800	0.36	0.44	2.18	1.62	0.52	0.43	7.3	1.18	0.043
630/50	0.0469	0.0634	0.36	0.44	2.14	1.65	0.51	0.49	6.5	1.33	0.041
800/50	0.0367	0.0512	0.36	0.44	2.11	1.67	0.49	0.54	5.9	1.49	0.039
1000/50	0.0291	0.0426	0.36	0.44	2.08	1.69	0.48	0.61	5.2	1.67	0.036



NOMINAL CROSS SECTIONAL AREA CONDUCTOR/ METALLIC SCREEN mm ²	INDUCTANCE L mH/km			INDUCTANCE REACTANCE XL Ω/km			IMPEDANCE Ω/km		
	0° 0° 2	000° 3	000° 4	0° 0° 2	000° 3	000° 4	0° 0° 2	000° 3	000° 4
	50/16	0.43	0.73	0.62	0.136	0.229	0.194	0.833	0.853
70/25	0.41	0.70	0.60	0.130	0.221	0.188	0.583	0.610	0.599
95/35	0.39	0.67	0.58	0.123	0.212	0.181	0.429	0.462	0.449
120/50	0.38	0.66	0.56	0.119	0.206	0.177	0.346	0.385	0.370
150/50	0.36	0.63	0.55	0.114	0.199	0.172	0.288	0.331	0.316
185/50	0.35	0.61	0.54	0.110	0.193	0.169	0.238	0.286	0.270
240/50	0.34	0.59	0.52	0.106	0.187	0.164	0.193	0.247	0.230
300/50	0.33	0.58	0.51	0.103	0.181	0.161	0.165	0.222	0.206
400/50	0.31	0.55	0.50	0.099	0.174	0.157	0.142	0.201	0.187
500/50	0.31	0.54	0.49	0.096	0.169	0.154	0.125	0.187	0.174
630/50	0.30	0.52	0.48	0.093	0.163	0.151	0.113	0.174	0.164
800/50	0.29	0.50	0.47	0.091	0.157	0.149	0.104	0.165	0.158
1000/50	0.28	0.48	0.46	0.088	0.151	0.146	0.098	0.157	0.152

- 2 - Cables in trefoil formation, the distance between cables De
3 - Cables in flat formation (in the ground), the distance between cables De + 70 mm
4 - Cables in flat formation (in the air), the distance between cables 2 × De

CURRENT RATING FOR SINGLE-CORE CABLES – AMPERES

NOMINAL CROSS SECTIONAL AREA mm ²	MAXIMUM SHORT CIRCUIT CAPACITY CONDUCTOR kA/sec	MAXIMUM SHORT CIRCUIT CAPACITY METALLIC SCREEN kA/sec	FLAT FORMATION		TREFOIL FORMATION		FLAT FORMATION		TREFOIL FORMATION	
			CONFIGURATIONS							
			SPP; CB	BOTH-ENDS	SPP; CB	BOTH-ENDS	SPP; CB	BOTH-ENDS	SPP; CB	BOTH-ENDS
			CABLES IN EARTH				CABLES IN AIR			
50/16	4.7	3.7	228	227	214	214	235	234	198	198
70/25	6.6	5.3	280	276	262	261	291	288	245	245
95/35	9.0	7.1	337	329	315	314	357	349	299	298
120/50	11.3	9.8	384	369	360	357	411	396	344	342
150/50	14.2	9.8	433	412	406	402	469	449	393	389
185/50	17.5	9.8	493	462	460	455	540	511	451	446
240/50	22.7	9.8	574	527	536	527	639	594	533	525
300/50	28.4	9.8	651	586	607	595	736	673	612	601
400/50	37.8	9.8	751	658	700	683	865	774	717	702
500/50	47.3	9.8	861	734	801	778	1009	880	836	813
630/50	59.5	9.8	990	818	917	884	1184	1003	976	944
800/50	75.6	9.8	1128	899	1037	992	1373	1126	1125	1080
1000/50	94.5	9.8	1276	983	1163	1103	1591	1255	1290	1228

SPB – Single Point Bonding; CB – Cross-bonding Both-ends; BE – Both-ends bonding

Laying conditions at trefoil formation are as below:

- Soil thermal resistivity: 1/2.5 k m/W
- Burial depth: 0.7m
- Ground temperature: 20°C | Ambient temperature: 30°C



DIMENSIONS 12/20 (24)kV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA		NOMINAL CONDUCTOR DIAMETER	NUMBER WIRES CONDUCTOR	NOM. THICKNESS SEMI-CON. LAYER		NOMINAL INSULATION THICKNESS	MINIMUM INSULATION THICKNESS	NOMINAL DIAMETER OVER INSULATION
		mm ²				INNER	OUTER			
		Conductor	Screen							
P9XAF20KV1050	1	50	16	8.20	7 x 2.90	0.50	0.40	5.50	4.85	20.4
P9XAF20KV1070	1	70	16	9.70	19 x 2.18	0.50	0.40	5.50	4.85	21.9
P9XAF20KV1095	1	95	16	11.4	19 x 2.55	0.50	0.40	5.50	4.85	23.6
P9XAF20KV1120	1	120	16	12.65	19 x 2.90	0.50	0.40	5.50	4.85	24.9
P9XAF20KV1150	1	150	25	14.4	19 x 3.16	0.50	0.40	5.50	4.85	26.6
P9XAF20KV1185	1	185	25	15.75	37 x 2.55	0.50	0.40	5.50	4.85	28.4
P9XAF20KV1240	1	240	25	18.2	37 x 2.90	0.50	0.40	5.50	4.85	30.9
P9XAF20KV1300	1	300	25	20.5	61 x 2.55	0.50	0.40	5.50	4.85	33.2
P9XAF20KV1400	1	400	35	23.0	61 x 2.90	0.50	0.40	5.50	4.85	35.7
P9XAF20KV1500	1	500	35	26.0	61 x 3.20	0.50	0.40	5.50	4.85	38.7
P9XAF20KV1630	1	630	35	30.2	61 x 3.65	0.50	0.40	5.50	4.85	42.9

NOMINAL CROSS SECTIONAL AREA	NUMBER WIRES SCREEN	DIAMETER TAPE SCREEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNESS	NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm ²	mm	mm	mm	mm	mm	kg/km	N/cm ²	N
50	44 x 0.66	1x0.1x10	1.80	1.24	27	700	292	1500
70	44 x 0.66	1x0.1x10	1.90	1.32	28	800	371	2100
95	44 x 0.66	1x0.1x10	1.90	1.32	30	900	479	2850
120	44 x 0.66	1x0.1x10	2.00	1.40	31	1000	550	3600
150	71 x 0.66	1x0.1x10	2.00	1.40	33	1300	633	4500
185	71 x 0.66	1x0.1x10	2.10	1.48	35	1400	729	5550
240	71 x 0.66	1x0.1x10	2.10	1.48	38	1600	870	7200
300	71 x 0.66	1x0.1x10	2.20	1.56	40	1900	992	9000
400	60 x 0.85	1x0.1x15	2.30	1.64	43	2250	1212	12000
500	60 x 0.85	1x0.1x15	2.40	1.72	46	2750	1389	15000
630	60 x 0.85	1x0.1x15	2.50	1.80	51	3250	1571	18900



ELECTRICAL CHARACTERISTICS 12/20 (24)kV

NOMINAL CROSS SECTIONAL AREA mm ²	CONDUCTOR DC RESISTANCE AT 20°C ohms/km	CONDUCTOR DC RESISTANCE AT 75°C ohms/km	CONDUCTOR AC RESISTANCE BY MAX TEMP ohms/km	CURRENT CARRYING CAPACITY (A)		REACTANCE ohms/km	CHARGING ADMITTANCE A/km	CAPACITANCE uF/km	S.C.C CONDUCTOR 1SEC kA	S.C.C SCREEN 1SEC kA	CONDUCTOR LOSSES IN THE GROUND kW/km
				In Ground 20°C	In Air 30°C						
50	0.641	1.32	0.825	195	217	0.19	0.39	0.15	4.70	3.2	31.4
70	0.443	0.917	0.570	237	270	0.18	0.37	0.17	6.58	3.2	32.0
95	0.32	0.662	0.412	282	328	0.18	0.35	0.19	8.93	3.2	32.8
120	0.258	0.524	0.328	320	378	0.17	0.34	0.20	11.28	3.2	33.6
150	0.203	0.426	0.268	353	425	0.17	0.33	0.22	14.10	5.0	33.4
185	0.164	0.339	0.213	396	485	0.17	0.32	0.24	17.39	5.0	33.4
240	0.125	0.258	0.160	457	573	0.16	0.31	0.27	22.56	5.0	34.0
300	0.100	0.207	0.132	511	652	0.16	0.30	0.29	28.20	5.0	34.5
400	0.0778	0.161	0.103	566	740	0.16	0.29	0.32	37.60	7.1	33.0
500	0.0605	0.125	0.0810	630	838	0.15	0.28	0.35	47.00	7.1	32.1
630	0.0469	0.0972	0.0640	701	882	0.15	0.27	0.40	59.22	7.1	47.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching)

Derating factor (air): 1 (Flat formation - touching)

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.



DIMENSIONS 18/30 (36)kV

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA		NOMINAL CONDUCTOR DIAMETER	NUMBER WIRES CONDUCTOR	NOM. THICKNESS SEMI-CON. LAYER		NOMINAL INSULATION THICKNESS	MINIMUM INSULATION THICKNESS	NOMINAL DIAMETER OVER INSULATION
		mm ²				INNER	OUTER			
		Conductor	Screen							
P9XAF30KV1050	1	50	16	8.20	7 x 2.90	0.50	0.40	8.00	7.10	25.2
P9XAF30KV1070	1	70	16	9.70	19 x 2.18	0.50	0.40	8.00	7.10	26.7
P9XAF30KV1095	1	95	16	11.4	19 x 2.55	0.50	0.40	8.00	7.10	28.4
P9XAF30KV1120	1	120	16	12.65	19 x 2.90	0.50	0.40	8.00	7.10	29.7
P9XAF30KV1150	1	150	25	14.4	19 x 3.16	0.50	0.40	8.00	7.10	31.4
P9XAF30KV1185	1	185	25	15.75	37 x 2.55	0.50	0.40	8.00	7.10	33.2
P9XAF30KV1240	1	240	25	18.2	37 x 2.90	0.50	0.40	8.00	7.10	35.7
P9XAF30KV1300	1	300	25	20.5	61 x 2.55	0.50	0.40	8.00	7.10	38.0
P9XAF30KV1400	1	400	35	23.0	61 x 2.90	0.50	0.40	8.00	7.10	40.5
P9XAF30KV1500	1	500	35	26.0	61 x 3.20	0.50	0.40	8.00	7.10	43.5
P9XAF30KV1630	1	630	35	30.2	61 x 3.65	0.50	0.40	8.00	7.10	47.7

NOMINAL CROSS SECTIONAL AREA	NUMBER WIRES SCREEN	DIAMETER TAPE SCREEN	NOMINAL SHEATH THICKNESS	MINIMUM SHEATH THICKNESS	NOMINAL OVERALL DIAMETER	NOMINAL WEIGHT	MAXIMUM SIDEWALL PRESSURE	MAXIMUM PULLING TENSION
mm ²	mm	mm	mm	mm	mm	kg/km	N/cm ²	N
50	44 x 0.66	1x0.1x10	2.00	1.40	32	1000	249	1500
70	44 x 0.66	1x0.1x10	2.00	1.40	34	1100	320	2100
95	44 x 0.66	1x0.1x10	2.10	1.48	36	1300	401	2850
120	44 x 0.66	1x0.1x10	2.10	1.48	37	1400	483	3600
150	71 x 0.66	1x0.1x10	2.20	1.56	39	1600	562	4500
185	71 x 0.66	1x0.1x10	2.20	1.56	41	1800	652	5550
240	71 x 0.66	1x0.1x10	2.30	1.64	43	2000	784	7200
300	71 x 0.66	1x0.1x10	2.40	1.72	46	2250	902	9000
400	60 x 0.85	1x0.1x15	2.50	1.80	49	2750	1111	12000
500	60 x 0.85	1x0.1x15	2.60	1.88	52	3250	1282	15000
630	60 x 0.85	1x0.1x15	2.70	1.96	56	3750	1462	18900



ELECTRICAL CHARACTERISTICS 18/30 (36)kV

NOMINAL CROSS SECTIONAL AREA mm ²	CONDUCTOR DC RESISTANCE AT 20°C ohms/km	CONDUCTOR DC RESISTANCE AT 75°C ohms/km	CONDUCTOR AC RESISTANCE BY MAX TEMP ohms/km	CURRENT CARRYING CAPACITY (A)		REACTANCE ohms/km	CHARGING ADMITTANCE A/km	CAPACITANCE uF/km	S.C.C CONDUCTOR 1SEC kA	S.C.C SCREEN 1SEC kA	CONDUCTOR LOSSES IN THE GROUND kW/km
				In Ground 20°C	In Air 30°C						
50	0.641	1.32	0.825	196	217	0.20	0.44	0.12	4.70	3.2	31.7
70	0.443	0.917	0.570	238	270	0.20	0.41	0.13	6.58	3.2	32.3
95	0.32	0.662	0.412	284	328	0.19	0.39	0.14	8.93	3.2	33.2
120	0.258	0.524	0.328	322	378	0.18	0.38	0.15	11.28	3.2	34.0
150	0.203	0.426	0.268	355	425	0.18	0.36	0.17	14.10	5.0	33.8
185	0.164	0.339	0.213	400	485	0.18	0.36	0.18	17.39	5.0	34.1
240	0.125	0.258	0.160	461	572	0.17	0.34	0.20	22.56	5.0	34.6
300	0.100	0.207	0.132	516	649	0.17	0.33	0.22	28.20	5.0	35.1
400	0.0778	0.161	0.103	572	737	0.16	0.32	0.24	37.60	7.1	33.7
500	0.0605	0.125	0.0810	638	835	0.16	0.31	0.26	47.00	7.1	33.0
630	0.0469	0.0972	0.0640	701	882	0.16	0.29	0.29	59.22	7.1	47.3

Derating factor (ground): 1 (Soil thermal resistivity: 1km/W, Depth 0.8m, Flat formation - touching)

Derating factor (air): 1 (Flat formation - touching)

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.