


BS 5467 Sectoral Shaped Copper Conductor Multi Core SWA 1.9/3.3kV Cable



ELAND CABLES ©

Eland Product Group: B9S

APPLICATION

Power and auxiliary control cables for use in power networks, underground in free-draining soil, outdoor and indoor applications and for use in cable ducting.

CHARACTERISTICS

Voltage Rating U₀/U
1.9/3.3kV

Temperature Rating
Maximum Operating: +90°C
Maximum Short-Circuit: +250°C

Minimum Bending Radius
12 x overall diameter

CONSTRUCTION

Conductor
Class 2 sectoral shaped stranded copper

Insulation
XLPE (Cross-Linked Polyethylene)

Separator
Polyester Tape

Filler
PVC (Polyvinyl Chloride)

Armour
SWA (Galvanised steel wire armour)

Outer Sheath
PVC (Polyvinyl Chloride)

Core Identification
● Brown ● Black ● Grey

Sheath Colour
● Black

STANDARDS

BS 5467, IEC 60502-1

Flame retardant to IEC/EN 60332-1
UV Resistant

THE CABLE LAB[®]

AN ISO/IEC 17025 AND IECCE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT

We are on a journey to Net Zero.

We've committed to near-term emissions reductions and a net-zero target with the Science Based Targets initiative and we're a signatory to the United Nations Global Compact Sustainable Development Goals.

Learn more about embodied carbon and our carbon emissions reduction actions, our comprehensive recycling services, and wider ESG activities for sustainable operations at: www.elandcables.com/company/about-us/esg-sustainability

SCIENCE
BASED
TARGETSBUSINESS
AMBITION FOR 1.5°C

REGULATORY COMPLIANCE

This cable is compliant with European Regulation EN 50575, the Construction Products Regulation.



This cable meets the requirements of the Low Voltage Directive 2014/35/EU, the RoHS Directive 2015/853/EU and Reach Directive EC 1907/2006. RoHS compliance has been tested and confirmed by The Cable Lab[®].

CE UK
CA



DIMENSIONS

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL THICKNESS OF INSULATION mm	MINIMUM THICKNESS OF OUTER SHEATH mm	NOMINAL OUTER DIAMETER mm	NOMINAL WEIGHT kg/km
B9S0335SBK	3	35	2.0	1.32	28	2124
B9S0350SBK	3	50	2.0	1.40	33	2930
B9S0370SBK	3	70	2.0	1.48	36	3739
B9S0395SBK	3	95	2.0	1.56	40	4734
B9S03120SBK	3	120	2.0	1.64	44	6047
B9S03150SBK	3	150	2.0	1.72	48	7196
B9S03185SBK	3	185	2.0	1.80	51	8565
B9S03240SBK	3	240	2.0	1.88	57	10645
B9S03300SBK	3	300	2.0	1.96	62	12709

ELECTRICAL CHARACTERISTICS

NOMINAL CROSS SECTIONAL AREA mm ²	CURRENT CARRYING CAPACITY A			MAXIMUM CONDUCTOR DC RESISTANCE AT 20°C Ω/km
	Clipped direct	In free air or on a perforated cable tray etc, horizontal or vertical at 30°C	Direct in ground or in ducting in ground, in or around buildings at 20°C	
	1 three or 1 four core cable, three-phase a.c or d.c	1 three or 1 four core cable, three-phase a.c or d.c	1 three or 1 four core cable, three-phase a.c or d.c	
35	154	162	115	0.524
50	187	197	135	0.387
70	238	251	167	0.268
95	289	304	197	0.193
120	335	353	223	0.153
150	386	406	251	0.124
185	441	463	281	0.0991
240	520	546	324	0.0754
300	599	628	365	0.0601

Air ambient temperature: 30°C
Ground ambient temperature: 20°C
Conductor operating temperature: 90°C

Notes

1. Where a conductor operates at a temperature exceeding 70°C it must be ascertained that the equipment connected to the conductor is suitable for the conductor operating temperature (see Regulation 512.1.2 of the 18th Edition of IEE Wiring Regulations).

2. Where cables in this table are connected to equipment or accessories designed to operate at a temperature not exceeding 70°C, the current ratings given in the equivalent table for 70°C thermoplastic insulated cables (Table 4D4A) must be used (see also Regulation 523.1 of the 18th Edition of IEE Wiring Regulations).

The above table is in accordance with Table 4E4A of the 18th Edition of IEE Wiring Regulations BS7671 and IEC 60364-5-52

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.